



PARTIAL ASSEMBLY

ITEM	DESCRIPTION
1	1" MPT x minimum 1.5" S Male Adapter
2	Minimum 1.5" Connection Piece
3	Minimum 3" x 3" x 1.5" SSS Tee
4	Minimum 3" Connection Piece

- Notes:
- 1) 2 DRAIN ASSEMBLIES REQUIRED PER MODULE (2 PER SIDE)
 - 2) FINAL ASSEMBLY LENGTH DETERMINED AT INSTALLATION
 - 3) ALL JOINTS TO BE MADE USING A PVC CEMENT UNLESS OTHERWISE STATED
 - 4) ALL PIPING AND FITTINGS < 3 INCH DIAMETER MUST BE A MINIMUM SCHEDULE 40 RATED
 - 5) MINIMUM PIPE SIZE DIAMETER FROM MODULE TO MAIN LINE IS 1.5 INCHES
 - 6) MINIMUM MAIN LINE DIAMETER TO SAMPLE CHAMBER IS 3 INCHES

Legend:

A	FIRST RELEASE	6/1/12
Rev.	DESCRIPTION	DATE



4106 Bernau Avenue - Greensboro, NC 27407
 Phone 336-547-9338 Fax 336-547-8559
 www.bnm-us.com

© Copyright Bord na Móna Environmental Products U.S. Inc.
 "Copyright and ownership of this drawing is vested in Bord na Móna Environmental Products U.S. Inc., whose prior written consent is required for its use, reproduction or for publication to any third party. All rights reserved by the law of copyright and by international copyright conventions are reserved to Bord na Móna Environmental Products U.S. Inc. and may be protected by court proceedings for damages and/or injunctions and costs."

Project PURAFLO PEAT FIBER BIOFILTER

Client CLIENT

Drawing Title DRAIN PIPE DETAIL

Date	Scale (A3)	Drawn by	Checked by	Approved by
6/1/12	N/S	AJW	PJ	PJ

Status	FOR APPROVAL <input type="checkbox"/>	Dwg. No.
PLANNING <input checked="" type="checkbox"/>	FOR CONSTRUCTION <input type="checkbox"/>	PURAFLO-03
TENDER <input type="checkbox"/>	AS BUILT <input type="checkbox"/>	